


Morsettiera X1	
1	+ SIRENA
2	- SIRENA
3	+ Elettrovalvola
4	- Elettrovalvola

Morsettiera X2	
1	+ 24V Alimentazione
2	A (n+1)
3	D (n+1)
4	0V
5	+ 12V Contatto apertura porta
6	+ 12V Alimentazione
7	A (n+2)
8	D (n+2)
9	Fn Comando Sirena
10	Fn Comando Elettrovalvola
11	abilitazione Elettrovalvola



IMPORTANTE :

CACCIALANZA & C. S.p.A. si riserva il diritto di modificare senza preavviso le informazioni contenute su questa scheda con il proposito di apportare miglioramenti alla produzione

IMPORTANT :

CACCIALANZA & C. S.p.A. reserves the right to change or modify without previous notice any data or specification due to changes or modification in order to improve the products presented

1	17.02.97	CAD				CA	CA					
0	23.01.95	EMESSO PER APPROVAZIONE				CA	CA					
Rev.	Date	Description				Drawn	Checked	Approved				
CACCIALANZA & C. s.p.a. ANTINCENDIO SICUREZZA ANTINQUINAMENTO SEGRATE (MILANO) - ITALY			Client / Project									
			Title SCHEDA 3SKKI V2 PER FMZ3 VISTA COMPONENTI									
										Date	Name	
										Drawn	23.01.95	CA
										Checked	23.01.95	CA
Approved												
Code 3193155809		Sys. 	Size A 3	Scale 1: 1	Dwg nr. 31049589			Rev. 1	Sheet 1 of 1			
THIS DRAWING IS THE PROPERTY OF CACCIALANZA & C. S.p.A. AND IS NOT TO BE REPRODUCED OR USED TO FURNISH ANY INFORMATION FOR MAKING OF DRAWINGS OR APPARATUS EXCEPT WHERE PROVIDED FOR BY AGREEMENT WITH SAID COMPANY												